



# Certificate of Compliance

**Certificate:** 1218640

**Master Contract:** 180161 (086957\_0\_000)

**Project:** 70102544

**Date Issued:** 2016-12-23

**Issued to:** Relpol S.A.  
Ul 11 Listopada 37  
Zary, 68-200  
POLAND

**Attention:** Tomasz Ochocki

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Reddiprasad Cheekoori*  
Reddiprasad Cheekoori

## **PRODUCTS**

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Relays R4 and R4N with suffixes, 4-pole, rated 250 VAC, 6 A, Res., Same Polarity, Coil rated 5 through 220 VDC, 6 through 240 VAC.

Relays RUC rated 250 VAC, 3 pole, 10 A, Res., and 2 pole, 15 A, Res., 2-pole, 15a, 150V ac, General Purpose, single phase; 2-pole, 10A, 250V ac, General Purpose, single phase; 2-pole, 10A, 28V dc, resistive; 2-pole, 1/3hp, 120V ac, single phase; 2-pole, 1/2hp, 240V ac, single phase; 2-pole, B300. 3-pole, 10A, 250V ac, General Purpose, single phase; 3-pole, 10A, 28V dc, resistive; 3-pole, 1/3hp, 120V ac, single phase (7.2 FLA); 3-pole, 1/2 hp, 240V ac, single phase (4.9 FLA); 3-pole, 1/2 hp, 240V ac, three-phase (2.2 FLA); 3-pole, B300, coil rated 6 through 220 VDC, 6 thorough 240 VAC.

Relays RUC-M rated 220VDC, 1 pole 12 A and 2 pole 4.5 A, General Purpose, Single phase, Q300

Relay Sockets SU4 and G4, rated 250 V, 6 A, Same Polarity.

Note: Open type devices are certified, as components, for use only in other certified equipment where the suitability of the combination is to be determined by CSA International.

## **APPLICABLE REQUIREMENTS**



**Certificate:** 1218640  
**Project:** 70102544

**Master Contract:** 180161  
**Date Issued:** 2016-12-23

---

CSA C22.2 No. 14 - Industrial Control Equipment



## *Supplement to Certificate of Compliance*

**Certificate:** 1218640

**Master Contract:** 180161 (086957\_0\_000)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70102544	2016-12-23	Update to the CSA report to add new relay model RUC-M based on previously certified model RUC.
2659152	2013-11-05	Original Certification of Model R4N based on redesign of previously Certified Model R4.
2585358	2013-01-15	Addition of recognized alternate plastic material for housing, coil bobbin, movable contact holder, base, insulated washer, mechanical indicator, push to test button and insulation barrier.