



Certificate of Compliance

Certificate: 1040367 (LR 86957-1)

Master Contract: 180161

Project: 2585359

Date Issued: January 23, 2013

Issued to: Relpol S.A.

Ul 11 Listopada 37

Zary, 68-200

Poland

Attention: Tomasz Ochocki

The products listed below are eligible to bear the CSA Mark shown



Simon Vorasane Eng.

Issued by: Simon Vorasane Eng.

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, Type R15 followed by 05, 10, 11, 12, 13 or 14, followed by 12, 13 or 14, followed by 2, followed by 3, followed by 1, 3, 5 or 6, followed by 006 through 240, may be followed by W1, W2, W3, may be followed by K or T, may be followed by L or N, may be followed by D, may be followed by S, open type with dust cover, 2, 3 or 4 pole double throw contacts, max ratings with suffix "05": 5A, 250V ac, 5A (res), 24V dc; with Suffix "10": 10A, 250V ac, 10A (res), 24V dc. Coils 240V ac or dc max; Type R15-WT, followed by 20, 21, 23 or 24, followed by 12 or 13, followed by 2, followed by 3, followed by 1, 3, 5 or P, followed by 006 through 240, may be followed by W, may be followed by T, may be followed by any combination of N, L, D or V, open type with dust cover, 2 or 3 pole double throw contacts, rated 250V ac max, 10 (res); 2-pole, 10A, 250V ac, General Purpose, single phase; 2-pole, 10A, 28V dc, resistive; 2-pole, 1/3 hp, 120V ac, single phase; 2-pole, 1/2 hp, 240V ac, single phase; 2-pole, B300 Pilot Duty Rating;

3-pole, 10A, 250V ac, General Purpose, single phase;

3-pole, 10A, 28V dc;

3-pole, 1/3hp, 120V ac, single phase

3-pole, 1/2 hp, 240V ac, single phase (4.9 FLA)

3-pole, 1/2 hp, 240V ac, three phase (2.2 FLA)

3-pole, B300 Pilot Duty Rating, coils 240V ac or DC max.



Certificate: 1040367 (LR 86957-1)

Master Contract: 180161

Project: 2585359

Date Issued: January 23, 2013

Relay sockets, Types GZ-8, -11, GZU-8, -11, PS-11, PZ-8, -11, max ratings: 10A, 250V ac, Type GZ-14, GZ-14U, 5A, 250V ac max.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-10 - Industrial Control Equipment